

CLIENT INFORMATION

Client: Corey McIlveen
Requested On: Feb 27, 2024
Phone: [REDACTED]
Email: [REDACTED]

hello@gosimplelab.com**EPA LAB ID:** CA01652**TESTING PERFORMED**

Testing Requested: PFAS Water Test
Matrix: Drinking Water
Testing / Report ID: R8MN5G

SAMPLE INFORMATION

Collection Date: Mar 10, 2024
Collected By: Corey McIlveen
Received Date: Mar 13, 2024
Reported On: Mar 19, 2024
Sample Location: Hose Bib

Sample Address: [REDACTED]**TESTING NOTES**

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	METHOD	EPA REG
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	0.49004031	0.0002	EPA 537.1	> HGL
Perfluorodecanoic acid	µg/L	0.05420232	0.0001	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroheptanoic acid	µg/L	0.02867050	0.0002	EPA 537.1	> HGL
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.0004	EPA 537.1	
Perfluorohexanoic acid	µg/L	0.00497635	0.0001	EPA 537.1	
Perfluorononanoic acid	µg/L	0.00109865	0.0002	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	0.67099737	0.0004	EPA 537.1	> HGL
Perfluorooctanoic acid	µg/L	0.00046780	0.0002	EPA 537.1	> HGL
Perfluorotetradecanoic acid	µg/L	0.00216505	0.0002	EPA 537.1	> HGL
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

HGL: Health Guidance Level. HGL is the highest concentration of an analyte which is deemed safe to consume before adverse health effects can occur.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. SLR is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the SLR over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin

CLIENT INFORMATION

Client: Corey McIlveen
Requested On: Feb 27, 2024
Phone: [REDACTED]
Email: [REDACTED]

hello@gosimplelab.com

EPA LAB ID: CA01652

TESTING PERFORMED

Testing Requested: PFAS Water Test
Matrix: Drinking Water
Testing / Report ID: R8MN6E

SAMPLE INFORMATION

Collection Date: Mar 10, 2024
Collected By: Corey McIlveen
Received Date: Mar 13, 2024
Reported On: Mar 19, 2024
Sample Location: Kitchen Sink

Sample Address: [REDACTED]

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	METHOD	EPA REG
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	0.00033900	0.0002	EPA 537.1	< HGL
Perfluorodecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroheptanoic acid	µg/L	0.00020339	0.0002	EPA 537.1	< HGL
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.0004	EPA 537.1	
Perfluorohexanoic acid	µg/L	0.00012725	0.0001	EPA 537.1	< HGL
Perfluorononanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	NOT DETECTED	0.0004	EPA 537.1	
Perfluorooctanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorotetradecanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

HGL: Health Guidance Level. HGL is the highest concentration of an analyte which is deemed safe to consume before adverse health effects can occur.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. SLR is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the SLR over the course of your lifetime is thought to be safe.

MOL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin

CLIENT INFORMATION

Client: Corey McIlveen
Requested On: Feb 27, 2024
Phone: [REDACTED]
Email: [REDACTED]

hello@gosimplelab.com**EPA LAB ID:** CA01652**TESTING PERFORMED**

Testing Requested: PFAS Water Test
Matrix: Drinking Water
Testing / Report ID: R8MN7F

SAMPLE INFORMATION

Collection Date: Mar 10, 2024
Collected By: Corey McIlveen
Received Date: Mar 13, 2024
Reported On: Mar 19, 2024
Sample Location: Bathroom

Sample Address: [REDACTED]**TESTING NOTES**

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact hello@gosimplelab.com

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	METHOD	EPA REG
N-ethyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
N-methyl perfluorooctanesulfonamidoacetic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorobutanesulfonic acid	µg/L	0.00054230	0.0002	EPA 537.1	< HGL
Perfluorodecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluorododecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroheptanoic acid	µg/L	0.00028670	0.0002	EPA 537.1	< HGL
Perfluorohexanesulfonic acid	µg/L	NOT DETECTED	0.0004	EPA 537.1	
Perfluorohexanoic acid	µg/L	0.00019765	0.0001	EPA 537.1	< HGL
Perfluorononanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorooctanesulfonic acid	µg/L	NOT DETECTED	0.0004	EPA 537.1	
Perfluorooctanoic acid	µg/L	0.00024573	0.0002	EPA 537.1	< HGL
Perfluorotetradecanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	
Perfluorotridecanoic acid	µg/L	NOT DETECTED	0.0001	EPA 537.1	
Perfluoroundecanoic acid	µg/L	NOT DETECTED	0.0002	EPA 537.1	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Federal Maximum Contaminant Level (MCL).

This is an enforceable primary drinking water standard set by the U.S. EPA. MCLs are the highest concentration of a contaminant permitted in drinking water from public water systems. MCLs are set as close as possible to health protective levels, while also taking into account the cost and availability of treatment technologies.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

HGL: Health Guidance Level. HGL is the highest concentration of an analyte which is deemed safe to consume before adverse health effects can occur.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. SLR is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the SLR over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin