

CLIENT INFORMATION

Client: Corey McIlveen
Requested On: Mar 5, 2025
Phone: [REDACTED]
Email: [REDACTED]

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:
support@mytapscore.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Essential City Water Test
Matrix: Drinking Water
Testing / Report ID: V7SJZA
Testing Facility: Symbio Laboratories
Facility Location: 8312 Miramar Mall
San Diego, California 92121

SAMPLE INFORMATION

Collection Date: May 5, 2025
Collected By: Corey McIlveen
Received Date: May 8, 2025
Reported On: May 15, 2025
Sample Location: Hose Bib
Sample Address: [REDACTED]

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
pH	pH	6.83	EPA 150.1	OK
Total Dissolved Solids	mg/L	724.7	SM 2510 B	
Hardness (Ca,Mg)	mg/L	213.05		
Hardness (Total)	mg/L	214.01		
Grains per gallon	Grains	12.5		
Alkalinity (as CaCO ₃)	mg/L	124.24	SM 2320 B	
Langelier Saturation Index		-1.5		
Sodium Adsorption Ratio		3.84		

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
Aluminum	mg/L	0.0424	0.00974	0.02922	EPA 200.7	< HGL
Antimony	mg/L	0.000139	0.00014	0.00042	EPA 200.8	< HGL
Arsenic	mg/L	0.0007968	5.0E-5	0.00016	EPA 200.8	> HGL (0)
Barium	mg/L	0.07145	9.0E-5	0.00027	EPA 200.7	< HGL
Beryllium	mg/L	NOT DETECTED	1.0E-5	5.0E-5	EPA 200.8	
Boron	mg/L	0.13137	0.00348	0.01043	EPA 200.7	< HGL
Cadmium	mg/L	3.0E-6	0	1.0E-5	EPA 200.8	< HGL

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Calcium	mg/L	55.27193	0.00319	0.00956	EPA 200.7	
Chloride	mg/L	203.95	0.007	0.2	EPA 300.1	
Chromium (Total)	mg/L	NOT DETECTED	0.00019	0.00056	EPA 200.8	
Cobalt	mg/L	4.0E-6	0	5.0E-5	EPA 200.8	< HGL
Copper	mg/L	0.01513	0.00039	0.00117	EPA 200.7	< HGL
Fluoride	mg/L	0.52	0.004	0.2	EPA 300.1	< HGL
Iron	mg/L	0.01076	0.00072	0.00215	EPA 200.7	< HGL
Lead	mg/L	0.0003029	2.0E-5	6.0E-5	EPA 200.8	> HGL (0)
Lithium	mg/L	0.08002	0.00017	0.0005	EPA 200.7	> HGL (0.01)
Magnesium	mg/L	18.22237	0.00037	0.0011	EPA 200.7	
Manganese	mg/L	0.00074	7.0E-5	0.00021	EPA 200.7	< HGL
Mercury	mg/L	NOT DETECTED	1.0E-5	4.0E-5	EPA 200.8	
Molybdenum	mg/L	0.0021457	1.0E-5	5.0E-5	EPA 200.8	< HGL
Nickel	mg/L	0.0003934	0.0001	0.00031	EPA 200.8	< HGL
Nitrate (as N)	mg/L	0.006	0.006	0.2	EPA 300.1	< HGL
Phosphorus	mg/L	NOT DETECTED	0.00587	0.01762	EPA 200.7	
Potassium	mg/L	5.22018	0.00068	0.00204	EPA 200.7	
Selenium	mg/L	0.000406	0.00041	0.00122	EPA 200.8	< HGL
Silver	mg/L	NOT DETECTED	1.0E-5	2.0E-5	EPA 200.8	
Sodium	mg/L	128.975	0.00017	0.0005	EPA 200.7	
Strontium	mg/L	0.60038	4.0E-5	0.00011	EPA 200.7	< HGL
Sulfate	mg/L	106.03	0.009	0.2	EPA 300.1	< HGL
Thallium	mg/L	NOT DETECTED	0	1.0E-5	EPA 200.8	
Tin	mg/L	0.0034	0.0034	0.01019	EPA 200.7	< HGL
Titanium	mg/L	NOT DETECTED	0.00028	0.00084	EPA 200.7	
Uranium	mg/L	0.0004917	3.0E-5	8.0E-5	EPA 200.8	> HGL (0)
Vanadium	mg/L	0.0015087	0.00017	0.0005	EPA 200.8	< HGL
Zinc	mg/L	0.0119	0.00044	0.00132	EPA 200.7	< HGL

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MOL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin



7L2MZ5

simplelab

CLIENT INFORMATION

Client: Corey Mcilveen
Requested On: Mar 5, 2025
Phone: [REDACTED]
Email: [REDACTED]

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:
support@mytapscore.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Essential City Water Test
Matrix: Drinking Water
Testing / Report ID: 7L2MZ5
Testing Facility: Symbio Laboratories
Facility Location: 8312 Miramar Mall
San Diego, California 92121

SAMPLE INFORMATION

Collection Date: May 5, 2025
Collected By: Corey McIlveen
Received Date: May 8, 2025
Reported On: May 15, 2025
Sample Location: Treated Sink
Sample Address: [REDACTED]

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
pH	pH	8.21	EPA 150.1	OK
Total Dissolved Solids	mg/L	743.2	SM 2510 B	
Hardness (Ca,Mg)	mg/L	228.41		
Hardness (Total)	mg/L	230.32		
Grains per gallon	Grains	14.64		
Alkalinity (as CaCO3)	mg/L	189.32	SM 2320 B	
Langelier Saturation Index		0.44		
Sodium Adsorption Ratio		3.16		

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
Aluminum	mg/L	NOT DETECTED	0.00974	0.02922	EPA 200.7	
Antimony	mg/L	NOT DETECTED	0.00014	0.00042	EPA 200.8	
Arsenic	mg/L	NOT DETECTED	5.0E-5	0.00016	EPA 200.8	
Barium	mg/L	0.01445	9.0E-5	0.00027	EPA 200.7	< HGL
Beryllium	mg/L	NOT DETECTED	1.0E-5	5.0E-5	EPA 200.8	
Boron	mg/L	0.12270	0.00348	0.01043	EPA 200.7	< HGL
Cadmium	mg/L	NOT DETECTED	0	1.0E-5	EPA 200.8	

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Calcium	mg/L	56.45130	0.00319	0.00956	EPA 200.7	
Chloride	mg/L	230.11	0.007	0.2	EPA 300.1	
Chromium (Total)	mg/L	NOT DETECTED	0.00019	0.00056	EPA 200.8	
Cobalt	mg/L	NOT DETECTED	0	5.0E-5	EPA 200.8	
Copper	mg/L	0.00056	0.00039	0.00117	EPA 200.7	< HGL
Fluoride	mg/L	NOT DETECTED	0.004	0.2	EPA 300.1	
Iron	mg/L	NOT DETECTED	0.00072	0.00215	EPA 200.7	
Lead	mg/L	NOT DETECTED	2.0E-5	6.0E-5	EPA 200.8	
Lithium	mg/L	0.00945	0.00017	0.0005	EPA 200.7	< HGL
Magnesium	mg/L	26.63156	0.00037	0.0011	EPA 200.7	
Manganese	mg/L	NOT DETECTED	7.0E-5	0.00021	EPA 200.7	
Mercury	mg/L	NOT DETECTED	1.0E-5	4.0E-5	EPA 200.8	
Molybdenum	mg/L	NOT DETECTED	1.0E-5	5.0E-5	EPA 200.8	
Nickel	mg/L	NOT DETECTED	0.0001	0.00031	EPA 200.8	
Nitrate (as N)	mg/L	NOT DETECTED	0.006	0.2	EPA 300.1	
Phosphorus	mg/L	NOT DETECTED	0.00587	0.01762	EPA 200.7	
Potassium	mg/L	5.33374	0.00068	0.00204	EPA 200.7	
Selenium	mg/L	NOT DETECTED	0.00041	0.00122	EPA 200.8	
Silver	mg/L	NOT DETECTED	1.0E-5	2.0E-5	EPA 200.8	
Sodium	mg/L	115.103	0.00017	0.0005	EPA 200.7	
Strontium	mg/L	0.00046	4.0E-5	0.00011	EPA 200.7	
Sulfate	mg/L	79.03	0.009	0.2	EPA 300.1	< HGL
Thallium	mg/L	NOT DETECTED	0	1.0E-5	EPA 200.8	
Tin	mg/L	NOT DETECTED	0.0034	0.01019	EPA 200.7	
Titanium	mg/L	NOT DETECTED	0.00028	0.00084	EPA 200.7	
Uranium	mg/L	NOT DETECTED	3.0E-5	8.0E-5	EPA 200.8	
Vanadium	mg/L	NOT DETECTED	0.00017	0.0005	EPA 200.8	
Zinc	mg/L	0.001406	0.00044	0.00132	EPA 200.7	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MOL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin



CLIENT INFORMATION

Client: Corey McIlveen
Requested On: Mar 5, 2025
Phone: [REDACTED]
Email: [REDACTED]

Kitting, Logistics, and Support provided by: SimpleLab, Inc.

Questions? For fastest assistance:
support@mytapscore.com
Do not contact facility technicians directly.

TESTING PERFORMED

Testing Requested: Essential City Water Test
Matrix: Drinking Water
Testing / Report ID: A9T3X3
Testing Facility: Symbio Laboratories
Facility Location: 8312 Miramar Mall
San Diego, California 92121

SAMPLE INFORMATION

Collection Date: May 5, 2025
Collected By: Corey McIlveen
Received Date: May 8, 2025
Reported On: May 15, 2025
Sample Location: Kitchen Sink
Sample Address: [REDACTED]

TESTING NOTES

There were no problems with analytical events associated with this report unless noted. Quality control data is within laboratory defined or method specified acceptance limits except where noted. If you have any questions regarding these test results, please contact support@mytapscore.com

SUMMARY ANALYSIS

ANALYTE	UNIT	RESULT	METHOD	EVALUATION
pH	pH	7.02	EPA 150.1	OK
Total Dissolved Solids	mg/L	684.12	SM 2510 B	
Hardness (Ca,Mg)	mg/L	206.41		
Hardness (Total)	mg/L	207.91		
Grains per gallon	Grains	11.6		
Alkalinity (as CaCO3)	mg/L	133.87	SM 2320 B	
Langelier Saturation Index		-0.7		
Sodium Adsorption Ratio		3.67		

TEST RESULTS

ANALYTE	UNIT	RESULT	MDL	RL	METHOD	EVALUATION
Aluminum	mg/L	NOT DETECTED	0.00974	0.02922	EPA 200.7	
Antimony	mg/L	NOT DETECTED	0.00014	0.00042	EPA 200.8	
Arsenic	mg/L	NOT DETECTED	5.0E-5	0.00016	EPA 200.8	
Barium	mg/L	0.00145	9.0E-5	0.00027	EPA 200.7	< HGL
Beryllium	mg/L	NOT DETECTED	1.0E-5	5.0E-5	EPA 200.8	
Boron	mg/L	0.10137	0.00348	0.01043	EPA 200.7	< HGL
Cadmium	mg/L	NOT DETECTED	0	1.0E-5	EPA 200.8	

Use of this report can only be done in full, with no alterations or additions. SimpleLab maintains the right to enforce this and by accepting this report you agree to abide by this policy.

Calcium	mg/L	53.65168	0.00319	0.00956	EPA 200.7	
Chloride	mg/L	235.01	0.007	0.2	EPA 300.1	
Chromium (Total)	mg/L	NOT DETECTED	0.00019	0.00056	EPA 200.8	
Cobalt	mg/L	NOT DETECTED	0	5.0E-5	EPA 200.8	
Copper	mg/L	NOT DETECTED	0.00039	0.00117	EPA 200.7	
Fluoride	mg/L	0.0051	0.004	0.2	EPA 300.1	< HGL
Iron	mg/L	NOT DETECTED	0.00072	0.00215	EPA 200.7	
Lead	mg/L	NOT DETECTED	2.0E-5	6.0E-5	EPA 200.8	
Lithium	mg/L	0.0021457	0.00017	0.0005	EPA 200.7	< HGL
Magnesium	mg/L	17.63156	0.00037	0.0011	EPA 200.7	
Manganese	mg/L	NOT DETECTED	7.0E-5	0.00021	EPA 200.7	
Mercury	mg/L	NOT DETECTED	1.0E-5	4.0E-5	EPA 200.8	
Molybdenum	mg/L	NOT DETECTED	1.0E-5	5.0E-5	EPA 200.8	
Nickel	mg/L	NOT DETECTED	0.0001	0.00031	EPA 200.8	
Nitrate (as N)	mg/L	NOT DETECTED	0.006	0.2	EPA 300.1	
Phosphorus	mg/L	NOT DETECTED	0.00587	0.01762	EPA 200.7	
Potassium	mg/L	6.35407	0.00068	0.00204	EPA 200.7	
Selenium	mg/L	NOT DETECTED	0.00041	0.00122	EPA 200.8	
Silver	mg/L	NOT DETECTED	1.0E-5	2.0E-5	EPA 200.8	
Sodium	mg/L	121.156	0.00017	0.0005	EPA 200.7	
Strontium	mg/L	NOT DETECTED	4.0E-5	0.00011	EPA 200.7	
Sulfate	mg/L	79.03	0.009	0.2	EPA 300.1	< HGL
Thallium	mg/L	NOT DETECTED	0	1.0E-5	EPA 200.8	
Tin	mg/L	NOT DETECTED	0.0034	0.01019	EPA 200.7	
Titanium	mg/L	NOT DETECTED	0.00028	0.00084	EPA 200.7	
Uranium	mg/L	NOT DETECTED	3.0E-5	8.0E-5	EPA 200.8	
Vanadium	mg/L	NOT DETECTED	0.00017	0.0005	EPA 200.8	
Zinc	mg/L	NOT DETECTED	0.00044	0.00132	EPA 200.7	

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Health Guidance Level.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MDL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team is configured to measure.

How To Read Your SimpleLab PDF Report

Your results are being evaluated with the Simple Lab Recommendation.

This is a health protective, non-enforceable drinking water benchmark. HGL is based on the most protective human health benchmark used among public health agencies for a contaminant. Drinking water at or near the HGL over the course of your lifetime is thought to be safe.

MOL: Method Detection Limit. MDL is the lowest concentration of an analyte which testing instrumentation and the analysis team configured to measure.



Did you know?

This Tap Score report is easier to understand when viewed online.
Access in-depth information about every detection, including health risks and treatment solutions.

gosimplelab.com/signin